

Client:

Village of Salem
181 Main Street
Salem, NY 12865

Project:

Village of Salem
PWS# 5730106

CNA Environmental, LLC received the sample(s) associated with this batch in compliance with NYSDOH guidelines. The requested analysis methods and results are detailed in the following data summary reports. Any exceptions to method procedures are listed in the comments section below.

To meet the New York Sanitary Code for Public Drinking Water, Total Coliform must be absent or <1; all other analytes must be less than or equal to the MCL.

Metals:

Sample(s) meet the NYSDOH MCL criteria for the parameters shown in the results section.

Total Metals

Date Received: 03/29/16 10:15

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed	Notes
C014746-01	Iron	EPA 200.7 Rev 4.4	0.127	0.002	mg/L	0.3	Well #1	3/29/16 10:00	4/8/16 00:00	PE
C014746-02	Iron	EPA 200.7 Rev 4.4	0.009	0.002	mg/L	0.3	Well #2	3/29/16 10:10	4/8/16 00:00	PE
C014746-03	Iron	EPA 200.7 Rev 4.4	0.035	0.002	mg/L	0.3	Well #3	3/29/16 10:05	4/8/16 00:00	PE
Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed	Notes
C014746-01	Manganese	EPA 200.7 Rev 4.4	0.100	0.001	mg/L	0.3	Well #1	3/29/16 10:00	4/8/16 00:00	PE
C014746-02	Manganese	EPA 200.7 Rev 4.4	0.217	0.001	mg/L	0.3	Well #2	3/29/16 10:10	4/8/16 00:00	PE
C014746-03	Manganese	EPA 200.7 Rev 4.4	0.256	0.001	mg/L	0.3	Well #3	3/29/16 10:05	4/8/16 00:00	PE

CNA Environmental, LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Krzysztof Trafalski For Sara Bogardus, Field Coordinator