



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

Sample ID	JH1901416	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Drill Well #1 - Raw Water		
Date Collected	3/6/2019	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/16/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.119	<0.05 - 0.30	EPA 200.7	3/13/2019	11549
Manganese	0.105	<0.01 - 0.30	EPA 200.7	3/13/2019	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1901417	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Drill Well #2 - Raw Water		
<b>Date Collected</b>	3/6/2019	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	3/16/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0102	<0.05 - 0.30	EPA 200.7	3/13/2019	11549
Manganese	0.258	<0.01 - 0.30	EPA 200.7	3/13/2019	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1901418	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Drill Well #3 - Raw Water		
<b>Date Collected</b>	3/6/2019	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	3/16/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0199	<0.05 - 0.30	EPA 200.7	3/13/2019	11549
Manganese	0.369	<0.01 - 0.30	EPA 200.7	3/13/2019	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1901419	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Finished water		
<b>Date Collected</b>	3/6/2019	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	3/16/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0439	<0.05 - 0.30	EPA 200.7	3/13/2019	11549
Manganese	0.0858	<0.01 - 0.30	EPA 200.7	3/13/2019	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample