page 1 of 1

### SAMPLE INFORMATION

Sample ID JH1803874 Customer Code 1952

Federal Water Supply Code NY5730106

Water Supply Town of Salem Water Department

Address PO Box 575 , Salem , NY , 12865

Sample Location Drilled Well # 1 RAW water

Date Collected 6/7/2018 Free Chlorine Temperature

Sample Collector Eric Rogers

Date Printed 6/21/2018

## LABORATORY REPORT

ANALYTE	CENTRATION	MG/L MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.145	<0.05 - 0.30	EPA 200.7	6/19/2018	10795
Manganese	0.127	<0.01 - 0.30	EPA 200.7	6/19/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium Aluminum, Dissolved			EPA 200.7 EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

 $<sup>^{\</sup>star\star\star}$  Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restristed sodiium diets.

Legend: NT= Not Tested

Notes:			

The above test procedures meet all the requirements of NELAC and relate only to this sample

page 2 of 1

#### SAMPLE INFORMATION

Sample ID JH1803875 Customer Code 1952

Federal Water Supply Code NY5730106

Water Supply Town of Salem Water Department

Address PO Box 575 , Salem , NY , 12865

Sample Location Drilled Well # 2 RAW water

Date Collected 6/7/2018 Free Chlorine Temperature

Sample Collector Eric Rogers

Date Printed 6/21/2018

## LABORATORY REPORT

ANALYTE CO	NCENTRATION	MG/L MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	6/19/2018	10795
Manganese	0.242	<0.01 - 0.30	EPA 200.7	6/19/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium Aluminum, Dissolved			EPA 200.7 EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

 $<sup>^{\</sup>star\star\star}$  Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restristed sodiium diets.

Legend: NT= Not Tested

Notes:		

The above test procedures meet all the requirements of NELAC and relate only to this sample

### SAMPLE INFORMATION

Sample ID JH1803876 Customer Code 1952

Federal Water Supply Code NY5730106

Water Supply Town of Salem Water Department

Address PO Box 575 , Salem , NY , 12865

Sample Location Drilled Well # 3 RAW water

Date Collected 6/7/2018 Free Chlorine Temperature

Sample Collector Eric Rogers

Date Printed 6/21/2018

## LABORATORY REPORT

ANALYTE CON	CENTRATION	MG/L MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0514	<0.05 - 0.30	EPA 200.7	6/19/2018	10795
Manganese	0.270	<0.01 - 0.30	EPA 200.7	6/19/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium Aluminum, Dissolved			EPA 200.7 EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

 $<sup>^{\</sup>star\star\star}$  Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restristed sodiium diets.

Legend: NT= Not Tested

Notes:	

The above test procedures meet all the requirements of NELAC and relate only to this sample

page 3 of 1

page 4 of 1

### SAMPLE INFORMATION

Sample ID JH1803877 Customer Code 1952

Federal Water Supply Code NY5730106

Water Supply Town of Salem Water Department

Address PO Box 575 , Salem , NY , 12865

Sample Location Finished water tap

Date Collected 6/7/2018 Free Chlorine Temperature

Sample Collector Eric Rogers

Date Printed 6/21/2018

## LABORATORY REPORT

ANALYTE	CENTRATION	MG/L MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0562	<0.05 - 0.30	EPA 200.7	6/19/2018	10795
Manganese	0.0814	<0.01 - 0.30	EPA 200.7	6/19/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium Aluminum, Dissolved			EPA 200.7 EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

 $<sup>^{\</sup>star\star\star}$  Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restristed sodiium diets.

Legend: NT= Not Tested

Notes:	

The above test procedures meet all the requirements of NELAC and relate only to this sample