

Lab ID: C016806-01

Date Collected: 06/15/16 06:30

Matrix: Drinking Water

Sample ID: Well #1

Date Received: 06/15/16 13:41

Total Metals by EPA 200.8

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Manganese	104		ug/L	0.02	0.5	EPA 200.8	06/27/16 14:44	06/27/16	50

Total Metals by SM3111B

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Iron	0.18		mg/L	0.031	0.10	SM 3111 B	06/23/16 12:40	06/23/16	0.3

CNA Environmental, LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Krzysztof Trafalski For Pam J. Higgins-Brown, Head of Front Office

Lab ID: C016806-02

Date Collected: 06/15/16 06:45

Matrix: Drinking Water

Sample ID: Well #2

Date Received: 06/15/16 13:41

Total Metals by EPA 200.8

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Manganese	258		ug/L	0.02	0.5	EPA 200.8	06/27/16 14:47	06/27/16	50

Total Metals by SM3111B

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Iron	ND	U	mg/L	0.031	0.10	SM 3111 B	06/23/16 12:40	06/23/16	0.3

CNA Environmental, LLC



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Krzysztof Trafalski For Pam J. Higgins-Brown, Head of Front Office

Lab ID: C016806-03

Date Collected: 06/15/16 06:35

Matrix: Drinking Water

Sample ID: Well #3

Date Received: 06/15/16 13:41

Total Metals by EPA 200.8

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Manganese	318		ug/L	0.02	0.5	EPA 200.8	06/27/16 14:49	06/27/16	50

Total Metals by SM3111B

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Prepared</u>	<u>MCL</u>
Iron	ND	U	mg/L	0.031	0.10	SM 3111 B	06/23/16 12:40	06/23/16	0.3

CNA Environmental, LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Krzysztof Trafalski For Pam J. Higgins-Brown, Head of Front Office