



PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1807199	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 575 , Salem , NY , 12865		
Sample Location	Drill Well #1 - Raw Water		
Date Collected	9/5/2018	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/24/2018		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron ,Total	0.128	<0.05 - 0.30	EPA 200.7	9/17/2018	11549
Manganese , Total	0.102	<0.01 - 0.30	EPA 200.7	9/17/2018	11549

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1807200	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 575 , Salem , NY , 12865		
Sample Location	Drill Well #2 - Raw Water		
Date Collected	9/5/2018	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/24/2018		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron ,Total	0.0138	<0.05 - 0.30	EPA 200.7	9/17/2018	11549
Manganese , Total	0.301	<0.01 - 0.30	EPA 200.7	9/17/2018	11549

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1807201	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 575 , Salem , NY , 12865		
Sample Location	Drill Well #3 - Raw Water		
Date Collected	9/5/2018	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/24/2018		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron ,Total	0.285	<0.05 - 0.30	EPA 200.7	9/17/2018	11549
Manganese , Total	0.686	<0.01 - 0.30	EPA 200.7	9/17/2018	11549

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1807202	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 575 , Salem , NY , 12865		
Sample Location	Finished Water		
Date Collected	9/5/2018	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/24/2018		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron ,Total	0.0531	<0.05 - 0.30	EPA 200.7	9/17/2018	11549
Manganese , Total	0.0852	<0.01 - 0.30	EPA 200.7	9/17/2018	11549

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample