



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

Sample ID	JH1906780	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Finished Water		
Date Collected	9/10/2019	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/26/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION	MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron			<0.05 - 0.30	EPA 200.7		
Dissolved Manganese			<0.01 - 0.30	EPA 200.7		
Iron	0.0674		<0.05 - 0.30	EPA 200.7	9/23/2019	11549
Manganese	0.0936		<0.01 - 0.30	EPA 200.7	9/23/2019	11549
Thallium			0.002	EPA 200.8		
Sodium			***	EPA 200.7		
Aluminum				EPA 200.7		
Calcium				EPA 200.7		
Aluminum, Dissolved				EPA 200.7		
Total Dissolved Solids				SM2540C		
Ammonia				EPA 350.1		
Nickel						

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

Sample ID	JH1906781	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #1		
Date Collected	9/10/2019	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/26/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION	MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron			<0.05 - 0.30	EPA 200.7		
Dissolved Manganese			<0.01 - 0.30	EPA 200.7		
Iron	0.134		<0.05 - 0.30	EPA 200.7	9/23/2019	11549
Manganese	0.103		<0.01 - 0.30	EPA 200.7	9/23/2019	11549
Thallium			0.002	EPA 200.8		
Sodium			***	EPA 200.7		
Aluminum				EPA 200.7		
Calcium				EPA 200.7		
Aluminum, Dissolved				EPA 200.7		
Total Dissolved Solids				SM2540C		
Ammonia				EPA 350.1		
Nickel						

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

Sample ID	JH1906782	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #2		
Date Collected	9/10/2019	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/26/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION	MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron			<0.05 - 0.30	EPA 200.7		
Dissolved Manganese			<0.01 - 0.30	EPA 200.7		
Iron	0.0580		<0.05 - 0.30	EPA 200.7	9/23/2019	11549
Manganese	0.304		<0.01 - 0.30	EPA 200.7	9/23/2019	11549
Thallium			0.002	EPA 200.8		
Sodium			***	EPA 200.7		
Aluminum				EPA 200.7		
Calcium				EPA 200.7		
Aluminum, Dissolved				EPA 200.7		
Total Dissolved Solids				SM2540C		
Ammonia				EPA 350.1		
Nickel						

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

Sample ID	JH1906783	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #3		
Date Collected	9/10/2019	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	9/26/2019		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.111	<0.05 - 0.30	EPA 200.7	9/23/2019	11549
Manganese	0.575	<0.01 - 0.30	EPA 200.7	9/23/2019	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample