

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105830
 WATER SUPPLY Town of Salem Water Department
 CUSTOMER NAME 23 East Broadway
 ADDRESS
 DATE LAST USED 7/12/2021 TIME LAST USED 6:00 PM
 DATE COLLECTED 7/13/2021 TIME COLLECTED 7:30 AM
 SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
 HOURS OF NON USE 13.5

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.0098	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021

JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105827
WATER SUPPLY Town of Salem Water Department
CUSTOMER NAME 25 Blind Buck Rd
ADDRESS
DATE LAST USED 7/12/2021 TIME LAST USED 8:00 PM
DATE COLLECTED 7/13/2021 TIME COLLECTED 6:00 AM
SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
HOURS OF NON USE 10

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.0212	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021

JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105831
WATER SUPPLY Town of Salem Water Department
CUSTOMER NAME 36 East Broadway
ADDRESS
DATE LAST USED 7/12/2021 TIME LAST USED 10:00 PM
DATE COLLECTED 7/13/2021 TIME COLLECTED 6:00 AM
SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
HOURS OF NON USE 8

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.0652	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021

JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105834
WATER SUPPLY Town of Salem Water Department
CUSTOMER NAME 27 Vale St
ADDRESS
DATE LAST USED 7/12/2021 TIME LAST USED 9:30 PM
DATE COLLECTED 7/13/2021 TIME COLLECTED 5:30 AM
SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
HOURS OF NON USE 8

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	0.0018	7/23/21	
COPPER	0.115	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021

JH CONSULTING GROUP, INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105835
 WATER SUPPLY Town of Salem Water Department
 CUSTOMER NAME 11 McDougal St
 ADDRESS
 DATE LAST USED 7/12/2021 TIME LAST USED 10:45 PM
 DATE COLLECTED 7/13/2021 TIME COLLECTED 5:15 AM
 SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
 HOURS OF NON USE 6.5

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.125	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample
 Date Printed 10/14/2021

JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105833
WATER SUPPLY Town of Salem Water Department
CUSTOMER NAME 18 Stanton Hill Rd
ADDRESS
DATE LAST USED 7/12/2021 TIME LAST USED 10:30 PM
DATE COLLECTED 7/13/2021 TIME COLLECTED 5:15 AM
SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
HOURS OF NON USE 6.75

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.129	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105959
 WATER SUPPLY Town of Salem Water Department
 CUSTOMER NAME 350 North Main St
 ADDRESS
 DATE LAST USED 7/13/2021 TIME LAST USED 11:55 PM
 DATE COLLECTED 7/14/2021 TIME COLLECTED 7:05 AM
 SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
 HOURS OF NON USE 7

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	9/29/21	11549
COPPER	0.150	9/29/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample
 Date Printed 10/14/2021

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105832
 WATER SUPPLY Town of Salem Water Department
 CUSTOMER NAME 4 Blanchard St
 ADDRESS
 DATE LAST USED 7/12/2021 TIME LAST USED 10:30 PM
 DATE COLLECTED 7/13/2021 TIME COLLECTED 7:30 AM
 SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
 HOURS OF NON USE 9

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.193	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample
 Date Printed 10/14/2021

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105829
 WATER SUPPLY Town of Salem Water Department
 CUSTOMER NAME 31 Riley Hill Rd
 ADDRESS
 DATE LAST USED 7/12/2021 TIME LAST USED 8:00 PM
 DATE COLLECTED 7/13/2021 TIME COLLECTED 5:30 AM
 SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
 HOURS OF NON USE 9.5

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.342	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample
 Date Printed 10/14/2021

JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

FIRST DRAW LEAD AND COPPER SAMPLING RESULTS

SUPPLY CODE 1952 SAMPLE ID 2105828
WATER SUPPLY Town of Salem Water Department
CUSTOMER NAME 49 Archibald St
ADDRESS
DATE LAST USED 7/12/2021 TIME LAST USED 10:00 PM
DATE COLLECTED 7/13/2021 TIME COLLECTED 6:00 AM
SAMPLE LOCATION KITCHEN TAP BATHROOM TAP OTHER
HOURS OF NON USE 8

<u>PARAMETER</u>	<u>CONCENTRATION mg/L</u>	<u>Date Analyzed</u>	<u>LAB</u>
LEAD	<0.0010	7/23/21	
COPPER	0.372	7/23/21	

COMMENTS

The United States Environmental Protection Agency sets drinking water standards and has determined that lead is a health concern at certain exposure levels. Public water systems that have lead concentrations below 0.015 mg/L and copper concentrations below 1.3 mg/l in more than 90% of their tap water samples have optimized their corrosion control. If your measured concentration exceeds these values you can reduce exposure to lead and/or copper by allowing the water to run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds.

The above test procedures meet all the requirements of NELAC and relate only to this sample

Date Printed 10/14/2021