Queensbury Laboratory Accredited in accordance with NELAC

Queensbury Water Department

823 Corinth Rd

Queensbury, N.Y. 12804-9725

(518) 793-8866

New York State Certification # 10565

EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 8/30/2017

Date Tested: 8/30/2017

Collected By: Eric Rogers

Sample Point: Bathroom Faucet

Address of Sample: 23 West Broadway Apt 2 Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 91358

Time Collected: 11:50 AM

Time Tested: 2:35 PM

Sample Age (hours)

2.75

Total Coliform (#/100ml): <1

Heterotrophic Plate Count (#/1ml): 29

E. Coli:

Field tested Free Chlorine: 1.27

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 18-22 9222A,B,C (-97)/40 CFR 141.

Standard Plate Count

SM18-22 9215B (-00)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:

Susan Sheehan

Laboratory Director or Designee