

**Queensbury Laboratory**  
**Accredited in accordance with NELAC**

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

**Report of Bacteriological Examination**

---

Date Collected: 11/18/2019

Date Tested: 11/18/2019

Collected By: Eric Rogers

Sample Point: Kitchen Faucet

Address of Sample: Proudfit Hall- 181 Main St Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 94910

Time Collected: 9:00 AM

Time Tested: 1:30 PM

Sample Age (hours)

4.50

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.62

---

**Procedures Used:**

Coliform, Total / E. coli (Qualitative) SM 21, 23 9222A,B,C

E. coli (Enumeration) SM 21, 23 9222A,B,C

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

**At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.**

**Sample Qualifier:**

*Susan Sheehan*

Laboratory Director or Designee