



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH1705271	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 214	, Salem	, NY , 12865
Sample Location	Drilled well # 1 raw water		
Date Collected	7/24/2017	Time Collected	9:10 AM
Sample Collector	Eric Rogers	E-Mail	SalemVwd@Verizon.net
Date Printed	7/24/17		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<i>INORGANICS Table 8C</i>					
		set up time			
Nitrate	<0.23	15:00	Hach 10206	10 mg/l as N	7/24/2017 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; < = Less Than; > = Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH1705272	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 214	, Salem	, NY , 12865
Sample Location	Drilled well # 2 raw water		
Date Collected	7/24/2017	Time Collected	9:05 AM
Sample Collector	Eric Rogers	E-Mail	SalemVwd@Verizon.net
Date Printed	7/24/17		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<i>INORGANICS Table 8C</i>					
		set up time			
Nitrate	0.703	15:00	Hach 10206	10 mg/l as N	7/24/2017 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; < = Less Than; > = Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH1705273	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	Glens Falls
Water Supply	Town of Salem Water Department		
Address	PO Box 214	, Salem	, NY , 12865
Sample Location	Drilled well # 3 raw water		
Date Collected	7/24/2017	Time Collected	9:00 AM
Sample Collector	Eric Rogers	E-Mail	SalemVwd@Verizon.net
Date Printed	7/24/17		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<i>INORGANICS Table 8C</i>					
		set up time			
Nitrate	0.917	15:00	Hach 10206	10 mg/l as N	7/24/2017 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; < = Less Than; > = Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples