



JH CONSULTING GROUP,
 INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1605902	Supply Code	1952
Federal Water Supply Code	NY5730106		
Public Water Supply	Town of Salem Water Department		
Address	PO Box 214	City	Salem
		State	NY
		Zip	12865
Sample Location	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap		
Date Collected	7/18/2016	Time Collected	9:25 AM
		Free Chlorine	0.68ng/L
Sample Collector	Eric Rogers		
Date Printed	8/1/2016		

EPA METHOD 524.2 Trihalomethanes (THM's)	Date Analyzed 7/25/16	NYS Lab 11216
---	-----------------------	---------------

ANALYTE	CONCENTRATION UG/L	MCL*	<u>METHOD</u>
Chloroform	4.75		EPA 524.2
Bromodichloromethane	1.72		EPA 524.2
Chlorodibromomethane	0.530		EPA 524.2
Bromoform	<0.500		EPA 524.2
Total Trihalomethane	7.00	80 ug/l	

Notes:

MCL* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample