

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, SALEM, NY 12865 phone and fax 854-9712

MONTHLY REPORT

August 10th 2016

- There are 309 meters in service.
- I attended a free water school put on by the Mueller Comp. I got 6 hrs. Credits for the class.
- We did 2 extra required water samples this month. The 1st one is Nitrate (we passed all 3). This was 1 sample at each well before treatment. The other test we did was Haloacetic Acids and Trihalomethanes both passed. This sample was taken at the Salem Rescue Squad, 152 E Broadway because that where it has been taken in the past so we can have something to compare to.
- The Salem Rescue Squad is where we did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225. "Passed"
- Regular upkeep and maintenance was performed.
- I started to clean out valves. It is going good but a little slow. It takes 15-25 mins a valve average or so. I clean out the valve – clean the cap – then I open and close the valve to make sure it still works and to exercise it.
- We have been working on our list 1-7. Im in process of lining up dates and times to get the stuff done. **1-7 info on back**
- I have a copy of testing we did. If anyone wants to see them let me know and I will give you it. Everything passed except well #3 manganese. This is why we are going to pull and clean well #3 to try to get it better so it can go back on line.
- We have been flushing dead end fire hydrants to keep water moving so it will stay clean and drinkable.

**Thank You,
Eric Rogers
Class C Water Plant Operator**

- Next year we have 2 expensive tests come up. Primary Inorganic Chemicals and Synthetic Organic Chemicals.

#1

Bid out to do work – hopping August 31st around 8am.

\$4000 - \$3485= +\$515.00

#2

Bid out work price – August 8th we had computer issue's. This was done at that time.

\$1800 - \$1779.67 = +\$20.33

#3

Talked with Mark on the cleaning and inspection of well #3. We hope to be pulling the well on the 12th of September.

#4

Talked to part sales men 8/1/16 is getting me a tight number to see what we can get. Got numbers back now im trying to pinch the # to get what we need and limit stock at the same time. Hope to have numbers and totals together and place the order in a week or so.

#5

Looking into what testing equipment would be best for our system.

#6

8/9/16 “1pm” had meeting on new computer to read meters stuff – got no information. ??? don't know what to think now about the computer system.

#7

Done Placed order on 8/2/16. Order all in.

\$850 - \$849.99= +\$0.01

#1 +515.00

#2 +20.33

#3

#4

#5

#6

#7 +\$0.01

+\$535.34