

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

February 8th 7pm 2017

- There are 309 meters in service.
- There was no new water hook ups this month.
- Regular upkeep and maintenance was performed.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We had a wind storm that called a power alarm and over-voltage well #1 alarm. The auto dialer called me and I was able to fix the issue.
- I turned off water to 10 Nichol Street.
- There was one water meter freeze up this month – water was turned off and will be turned back on in the spring. Home owner will not be fixing till spring.
- We ordered some miner test equipment to better monitor the chlorine percent that is pumped into the lines. We get it at a 12.5% and as it gets older the percent goes down.
- Meter Read.
- There was one structure fire inside the Salem water district. Firemen used hydrant #41, we pumped the hydrant out to winterize it. All seemed to go good with the water systems side.

- There will be a water school in Saratoga this year. I will be signing up Travis and Myself to go to it to get needed credits.
- Water leak and Meter repair notice, going to mail out leak notice's based on the next meter read and also going to work on fixing house hold meters. I have to letters made up (what do you think of them) are they ok?

Thank You,

Eric Rogers

Class C Water Plant Operator

