

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

February 13th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We did a couple water turn offs for the winter to prevent freeze ups.
- We had 2 water issues that required turning off water to the buildings. 1 was left off / no one lives in one home and the other was turned back on the next day after they fixed there broken pipe.
- All Hydrants have been pumped out and are ready for winter. I ask if any hydrant is used to contact the water department so it can be re-pumped.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- All fire hydrants are in service.
- I would like to thank everyone that cleans around the fire hydrants.
- I did a monthly meter read.
- I am looking into going to the water school in Saratoga in the middle of April. This is a good way to get needed education - got info needed going to go to operators day (\$60) each for day.
- I got the info I needed to renewal of my water operators certificate. This is something needed to do every 3 years to keep up to date. I have all needed requirements and will mail out this month.

Thank You,

Eric Rogers

Class C Water Plant Operator

*Just got 2019 water testing requirements