

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

**June 14<sup>th</sup> 7pm 2017**

- I had to make a new email. My new email is salemwaterdept@gmail.com
- There are 310 meters in service.
- There was no new water hook ups this month.
- Finished up my Lead and Copper monitoring plan. I was able to meet with the Dept of Health and I got my plan approved.
- Regular upkeep and maintenance was performed.
- We will be starting our summer dead end fire hydrant flushing soon. This helps to keep the water moving in low water used spots.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- June's Ir & Mn test results will decide what well I will have pulled – cleaned and replaced this year so we can keep up on our 3 year plan for well cleaning and maintenance so we will not have to have all 3 wells done in one year. We did well #3 last year.
- I was able to talk to a person from Badger Meter. We will be meeting them on the week of the 19<sup>th</sup> of June to see what they can offer. Base numbers for the meter read update that is over do looks to be around \$8500. This number is way less than what was 1<sup>st</sup> thought.
- I was able to meet with Seth about reviewing EDU's – Rules and Regulations and Badger Meter stuff. We are working on updating and doing some small modifications and will have more info in the upcoming months.

Thank You,

**Eric Rogers**

Class C Water Plant Operator

In the upcoming months I am hoping to start doing my valve cleaning and operation. I also am planning to get Rural Water hear to see if they can do some leak detection for me to check the status of the system. I am planning in the fall to have a well pulled – cleaned and monitor installed like we did with well 3 last year.