

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

June 12th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We have been flushing dead end fire hydrants to keep water moving.
- had to put in valve risers and also fix a couple cub stops / highway paving
- We did our year end meter read.
- I have been working on cleaning and operating the main valves around the system. This is some of the yearly upkeep I try to do. All valves have been operated.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are in service
- I have changed a couple more no read meter heads. I hope to do more for them on rain days.
- We need to have the office door at the water barn replaced.
- Did flow tests on well #1 & #2. Started to do cleaning *

Thank You,

Eric Rogers

Class C Water Plant Operator

* July's report - In the 1st week and a half of June we have cleaned both well 1 and well 2. I also have got hydrant #37 repaired and back in service. The projects went good.