

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

June 9th 2021

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Have been working priming and painting fire hydrants and then install new bolts. I am hoping that the hydrant near the school will be painted by the school in Salem Generals colors like other water systems do. Working on 25 hydrants. I have about 10 left to finish.
- Passed boiler inspection (2 year)
- We did a hand full for Dig Safe mark outs.
- We did our 2nd round Iron and Manganese testing.
- We got back the PFOA, PFOS, and 1,4-Dioxane results. We tested good on them.
- The Highway helped to clean out back of water office area. Removed so old metal pipes and trimmed some tree's. They also got some slate off of the hill to the water barn and its behind the barn to be sold.
- We had a contractor hit a curb stop. Got them a bill for the repairs \$81.15. Still waiting to hear that they payed it.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced - will do in spring I hope.

Thank You,

Eric Rogers

Class C Water Plant Operator