

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

May 10th 7pm 2017

- There are 310 meters in service.
- There was no new water hook ups this month.
- Finished up my Lead and Copper monitoring plan. I have an apt in the middle of the month to double check it and get it approved.
- Regular upkeep and maintenance was performed.
- Fire Hydrant flushing was completed. We had 3 Hydrants with issues. 1 had a flow issue and 2 were hard to operate. All issues have been addressed and fixed. **ALL HYDRANTS GOOD ARE IN SERVICE.**
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- Travis and I went to a water school in Saratoga. We got some needed “CEU”. This was very informational.
- I was able to talk to a person from Badger Meter and I hope to be setting up a meeting with them on what they offer and what options there are for meter reading. There are more options than what we were 1st told.
- I was able to meet with Seth about reviewing EDU’s – Rules and Regulations and Badger Meter stuff. We are working on updating and doing some small modifications and will have more info in the upcoming months. I hope to have prices and info on meter reading by next meeting.

Thank You,

Eric Rogers

Class C Water Plant Operator

In the upcoming months I am hoping to start doing my valve cleaning and operation. I also am planning to get Rural Water hear to see if they can do some leak detection for me to check the status of the system. I am planning in the fall to have a well pulled – cleaned and monitor installed like we did with well 3 last year.