SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865 Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

November 13th Wednesday 7pm

- Washington County Department of Safety came out and did a water tank inspection for the Water Department of the out side of the tank. They did it with there drone. We got some good pictures and this saved us from having to climb the tank to look at it. The Department of Heath is happy the tank got inspected.
- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We did a hand full for Dig Safe mark outs.
- We did our yearly fall fire hydrant flushing. The flushing went good and there was no issue's. We did a water sample after and that came back good.
- All fire hydrants have been pumped out for winter. If a hydrant gets used please let the Water Department know so we can re-pump out. At that time I checked the hydrant oil and made sure all caps opened with no problems. All hydrants looked good.
- All Fire Hydrants are in service.
- Eye wash and Fire Extinguishers checks have been done. We had our yearly Fire Extinguisher inspection done. All looked good.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- I have been working on up dating some curb stop maps. I have relocated almost all of them. There is less than 10 that I can't find and some of them I don't think thee is one for.
- We need to have the office door at the water barn replaced. We have had it looked at.

• I am signed up for a **free** water school in Ballston Spa in December. The class is Line Location and Leak Detection.

Thank You,

Eric Rogers

Class C Water Plant Operator

•