

# SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

## November 11<sup>th</sup> Wednesday 7pm

- There are 315 meters in service.
  - Regular upkeep and maintenance was performed.
  - We have been flushing dead end fire hydrants to keep water moving.
  - We did a hand full for Dig Safe mark outs.
  - All Fire Hydrants are in service - and set for winter. I pumped them all out and made sure all caps can come off easy and also checked oil and changed markers that needed changing.
  - We did our fire hydrant flushing. It went good with out any issues. I re flushed all dead ends on the 3<sup>rd</sup> day.
  - Yearly fire extinguisher check was done.
  - Eye wash and Fire Extinguishers checks have been done.
  - We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
  - I have been working on up dating some curb stop maps - also started to add some highway drain stuff to the diamond mapping program.
  - We need to have the office door at the water barn replaced.
- 
- **If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze.**

**\* Hopefully all hydrant dead end flushing will be done til spring.**

Thank You,

**Eric Rogers**

Class C Water Plant Operator

