

FIRST DRAW LEAD MONITORING RESULTS

Date Printed 10/14/2021

<u>SAMPLE ID</u>	<u>WATER SUPPLY</u>	<u>CUSTOMER NAME</u>	<u>ADDRESS</u>	<u>DATE COLLECTED</u>	<u>HOURS OF NON USE</u>	<u>LEAD</u>	<u>Date Analyzed Lead</u>
2105827	Town of Salem Water Department	25 Blind Buck Rd		7/13/2021	10	<0.0010	7/23/21
2105828	Town of Salem Water Department	49 Archibald St		7/13/2021	8	<0.0010	7/23/21
2105829	Town of Salem Water Department	31 Riley Hill Rd		7/13/2021	9.5	<0.0010	7/23/21
2105830	Town of Salem Water Department	23 East Broadway		7/13/2021	13.5	<0.0010	7/23/21
2105831	Town of Salem Water Department	36 East Broadway		7/13/2021	8	<0.0010	7/23/21
2105832	Town of Salem Water Department	4 Blanchard St		7/13/2021	9	<0.0010	7/23/21
2105833	Town of Salem Water Department	18 Stanton Hill Rd		7/13/2021	6.75	<0.0010	7/23/21
2105835	Town of Salem Water Department	11 McDougal St		7/13/2021	6.5	<0.0010	7/23/21
2105959	Town of Salem Water Department	350 North Main St		7/14/2021	7	<0.0010	9/29/21
2105834	Town of Salem Water Department	27 Vale St		7/13/2021	8	0.0018	7/23/21

LEAD VALUES ARRANGED IN ASCENDING ORDER

**90th PERCENTILE LEAD CONCENTRATION** (HIGHLIGHTED IN YELLOW)

**If value is (greater than) >0.015 mg/l the Action Level is Exceeded  
 If value is (less than or equal to) ≤0.015 mg/l you are in Compliance**

values for lead and copper are in mg/L

Analysis performed for JH Consulting Group, Inc by NYS Lab 11549 , The above test procedures meet all the requirements of NELAC and relate only to these samples