



**PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839**

SAMPLE INFORMATION

Sample ID	JH2001609	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #1		
Date Collected	3/10/2020	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/18/2020		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0217	<0.05 - 0.30	EPA 200.7	3/17/2020	11549
Manganese	0.258	<0.01 - 0.30	EPA 200.7	3/17/2020	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH2001610	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #2		
Date Collected	3/10/2020	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/18/2020		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0112	<0.05 - 0.30	EPA 200.7	3/17/2020	11549
Manganese	0.259	<0.01 - 0.30	EPA 200.7	3/17/2020	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

[Empty box for notes]

The above test procedures meet all the requirements of NELAC and relate only to this sample



**PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839**

SAMPLE INFORMATION

Sample ID	JH2001611	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Water Well #3		
Date Collected	3/10/2020	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/18/2020		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0705	<0.05 - 0.30	EPA 200.7	3/17/2020	11549
Manganese	0.111	<0.01 - 0.30	EPA 200.7	3/17/2020	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839**

SAMPLE INFORMATION

Sample ID	JH2001612	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Finished Water		
Date Collected	3/10/2020	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/18/2020		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0546	<0.05 - 0.30	EPA 200.7	3/17/2020	11549
Manganese	0.0883	<0.01 - 0.30	EPA 200.7	3/17/2020	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample