



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1710137	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 575 , Salem , NY , 12865		
<b>Sample Location</b>	Drilled well # 1 raw water		
<b>Date Collected</b>	12/21/2017	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/9/2018		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.152	<0.05 - 0.30	EPA 200.7	1/3/2018	10795
Manganese	0.101	<0.01 - 0.30	EPA 200.7	1/3/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1710138	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 575 , Salem , NY , 12865		
<b>Sample Location</b>	Drilled well # 2 raw water		
<b>Date Collected</b>	12/21/2017	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/9/2018		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	1/3/2018	10795
Manganese	0.230	<0.01 - 0.30	EPA 200.7	1/3/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1710139	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 575 , Salem , NY , 12865		
<b>Sample Location</b>	Drilled well # 3 raw water		
<b>Date Collected</b>	12/21/2017	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/9/2018		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.277	<0.05 - 0.30	EPA 200.7	1/3/2018	10795
Manganese	0.676	<0.01 - 0.30	EPA 200.7	1/3/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1710140	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 575 , Salem , NY , 12865		
<b>Sample Location</b>	Finished Water - 53 Stanton Hill Rd, Water office		
<b>Date Collected</b>	12/21/2017	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/9/2018		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	1/3/2018	10795
Manganese	0.0960	<0.01 - 0.30	EPA 200.7	1/3/2018	10795
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes: