

JH CONSULTING, GROUP, INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

FIRST DRAW COPPER MONITORING RESULTS

Date Printed 10/14/2021

<u>SAMPLE ID</u>	<u>WATER SUPPLY</u>	<u>CUSTOMER NAME</u>	<u>ADDRESS</u>	<u>DATE COLLECTED</u>	<u>HOURS OF NON USE</u>	<u>COPPER</u>	<u>DATE ANALYZED</u>
2105830	Town of Salem Water Department	23 East Broadway		7/13/2021	13.5	0.0098	7/23/21
2105827	Town of Salem Water Department	25 Blind Buck Rd		7/13/2021	10	0.0212	7/23/21
2105831	Town of Salem Water Department	36 East Broadway		7/13/2021	8	0.0652	7/23/21
2105834	Town of Salem Water Department	27 Vale St		7/13/2021	8	0.115	7/23/21
2105835	Town of Salem Water Department	11 McDougal St		7/13/2021	6.5	0.125	7/23/21
2105833	Town of Salem Water Department	18 Stanton Hill Rd		7/13/2021	6.75	0.129	7/23/21
2105959	Town of Salem Water Department	350 North Main St		7/14/2021	7	0.150	9/29/21
2105832	Town of Salem Water Department	4 Blanchard St		7/13/2021	9	0.193	7/23/21
2105829	Town of Salem Water Department	31 Riley Hill Rd		7/13/2021	9.5	0.342	7/23/21
2105828	Town of Salem Water Department	49 Archibald St		7/13/2021	8	0.372	7/23/21

Copper VALUES ARRANGED IN ASCENDING ORDER

90th PERCENTILE COPPER CONCENTRATION (HIGHLIGHTED IN YELLOW)	If value is (greater than) >1.3 mg/l the Action Level is Exceeded If value is (less than or equal to) ≤1.3 mg/l you are in Compliance
---	---

Concentrations for lead and copper are in mg/L
 Analysis performed for JH Consulting Group, Inc by NYS Lab 11549 , The above test procedures meet all the requirements of NELAC and relate only to these samples