

NEW YORK STATE DEPARTMENT OF HEALTH
Bureau of Water Supply Protection

**Water Systems Open
Microbiological Sam**

Public Water System Name	Reporting Month/Year	Date Report Submitted	Source of Water Supply:
Town of Salem Water Department	October 2021	44501	
Public Water System ID	County	Town, Village, or City	
5730106	Washington	Town of Salem	

DATE	Treated water volume (1,000 gallons/day)		Chlorination				Other Treatments / Readings		
			Gaseous		Liquid	Free chlorine residual at entry point (mg/l)	orthophosphate residual		
			Cylinder weight (lbs.)	Chlorine used per day (lbs.)	Hypochlorite added to crock (gallons or quarts)				
1	36210					1.37	1.9		
2	53950					1.37	1.24		
3	35986					1.45	1.31		
4	53330					1.55	1.22		
5	35622					1.53	1.26		
6	49518					1.45	1.26		
7	69042					1.52	1.28		
8	31483					1.46	1.47		
9	52499					1.37	1.41		
10	41980					1.49	0.92		
11	41996					1.41	1.21		
12	150530				Hydrant Flushing	1.57	0.8		
13	144782				Hydrant Flushing	1.5	0.7		
14	58848					1.52	0.57		
15	33324					1.5	0.59		
16	36956					1.54	1.86		
17	39792					1.48	1.37		
18	52664					1.44	1.44		
19	49406					1.47	1.38		
20	36359					1.39	1.24		
21	67107					1.36	1.63		
22	39232					1.41	1.52		
23	50512					1.37	1.44		
24	34912					1.39	1.85		
25	44936					1.81	1.77		
26	43918					1.77	1.68		
27	63350					1.48	1.82		
28	83864					1.54	1.65		

29	43610					1.45	1.63		
30	39636					1.26	1.48		
31	40076					1.49	1.44		
Total	1655430	0		0	0		42.34	0	
AVG.	53400.9677	#DIV/0!		#DIV/0!	#DIV/0!	47451612	1.365806452	#DIV/0!	#DIV/0!

Does a M&AR violation exist? **No** Does an MCL violation exist **No** Population Served **915**

Did an emergency occur in any part of the water system? **No** Does the system have a disinfection waiver? **No**

Reported by Eric Rogers Title: Water Plant Operator Certification Number NY0036794

Signature: _____ Date: 44501 Operator Grade Level C