



JH CONSULTING GROUP,
 INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1904557	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Sample Location	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap		
Date Collected	7/9/2019	Time Collected	8:15 AM
Sample Collector	Eric Rogers	Free Chlorine	mg/L
Date Printed	7/29/2019		

EPA Method 552.2 Haloacetic Acids (HAA5)	Date Analyzed 7/19/2019	NYS Lab ID # 10142
---	-------------------------	--------------------

RESULTS

ANALYTE	CONCENTRATION UG/L	MCL *	<u>METHOD</u>
Dibromoacetic Acid	<1		EPA 552.2
Dichloroacetic Acid	3.16		EPA 552.2
Monobromoacetic Acid	<1		EPA 552.2
Monochloroacetic Acid	<2		EPA 552.2
Trichloroacetic Acid	1.81		EPA 552.2
Total Haloacetic Acid	4.97	60 µg/L	EPA 552.2

Notes:

MCL* is the Maximum Contaminant Level; In case of HAA5 the running average of the four most recent quarterly monitoring allowed in drinking water for a specific analyte as per NYS Sanitary Code.
 UG/L is Micrograms per Liter
 The above test procedures meet all the requirements of NELAC and related only to this sample