



JH CONSULTING GROUP,  
 INC  
 PO BOX 705  
 NEWTONVILLE, NY 12128  
 (518) 785-9839

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2105783	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Sample Location</b>	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap		
<b>Date Collected</b>	7/13/2021	<b>Time Collected</b>	8:45 AM
		<b>Free Chlorine</b>	0.11 mg/L
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	9/28/2021		

EPA Method 552.2 <b>Haloacetic Acids (HAA5)</b>	Date Analyzed 7/27/2021	NYS Lab ID # 11398
---	-------------------------	--------------------

**RESULTS**

<b>ANALYTE</b>	<b>CONCENTRATION UG/L</b>	<b>MCL *</b>	<b><u>METHOD</u></b>
Dibromoacetic Acid	<1.0		EPA 552.2
Dichloroacetic Acid	3.2		EPA 552.2
Monobromoacetic Acid	<1.0		EPA 552.2
Monochloroacetic Acid	<2.0		EPA 552.2
Trichloroacetic Acid	5.9		EPA 552.2
Total Haloacetic Acid	9.1	60 µg/L	

Notes:

MCL\* is the Maximum Contaminant Level; In case of HAA5 the running average of the four most recent quarterly monitoring allowed in drinking water for a specific analyte as per NYS Sanitary Code.

UG/L is Micrograms per Liter

The above test procedures meet all the requirements of NELAC and related only to this sample