

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 8/12/2020

Date Tested: 8/12/2020

Collected By: Eric Rogers

Sample Point: Kitchen Faucet

Address of Sample: Proudfit Hall- 181 Main St Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 95833

Time Collected: 9:00 AM

Time Tested: 1:45 PM

Sample Age (hours)

4.75

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.36

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 21, 23 9222A,B,C

E. coli (Enumeration) SM 21, 23 9222A,B,C

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 8/12/2020

Date Tested: 8/12/2020

Collected By: Eric Rogers

Sample Point: Well

Address of Sample: 53 Stanton Hill Rd Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 95832

Time Collected: 8:30 AM

Time Tested: 1:45 PM

Sample Age (hours)

5.25

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine:

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 21, 23 9222A,B,C

E. coli (Enumeration) SM 21, 23 9222A,B,C

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 8/13/2020
Date Tested: 8/13/2020
Collected By: Eric Rogers
Sample Point: Well Head

Sample Number: 95838
Time Collected: 10:00 AM
Time Tested: 3:10 PM

Address of Sample: 53 Stanton Hill Rd Salem, NY 12865-

Supplier: Salem Water Department
Fed Id: 5730106

Sample Age (hours)
5.17

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample
Heterotrophic Plate Count (#/1ml):
E. Coli:
Field tested Free Chlorine:

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 21, 23 9222A,B,C
E. coli (Enumeration) SM 21, 23 9222A,B,C
Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee