

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 02/15/2017	Sample Number: 90353
Date Tested: 02/15/2017	Time Collected: 10:15 AM
Collected By: Eric Rogers	Time Tested: 1:20 PM
Sample Point: Kitchen Faucet	
Address of Sample: 181 Main St., Proudfit Hall, Salem, NY	
Supplier: Salem Water Department	Sample Age (hours)
Fed Id: 5730106	3.08

Total Coliform (#/100ml): <1

Heterotrophic Plate Count (#/1ml):

E. Coli:


Field tested Free Chlorine: 1.31

Procedures Used:

Coliform, Total / E. coli (Qualitative)	SM 18-22 9222A,B,C (-97)/40 CFR
Standard Plate Count	SM18-22 9215B (-00)
E. coli (Enumeration)	SM18-22 9222A,B,C 9-97)/40 CFR

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee