

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 5/25/2016

Date Tested: 5/25/2016

Collected By: Eric Rogers

Sample Point: Kitchen Faucet

Address of Sample: 181 North Main Street Salem, NY 12865-

Supplier: Salem (Village of)

Fed Id: 5730106

Sample Number: 88813

Time Collected: 7:15 AM

Time Tested: 1:10 PM

Sample Age (hours)

5.92

Total Coliform (#/100ml): <1

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 2.01

Procedures Used:


Coliform, Total / E. coli (Qualitative) SM 18-22 9222A,B,C (-97)/40 CFR

Standard Plate Count SM18-22 9215B (-00)

E. coli (Enumeration) SM18-22 9222A,B,C 9-97)/40 CFR

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee