



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

PFOA

Sample ID JH2100014
 Federal Water Supply Code NY5730106 Supply Code 1952
 Water Supply Town of Salem Water Department
 Address PO Box 57, 53 Stanton Salem NY 12865
 Sample Location Treatment Plant TP-01
 Date Collected 1/4/2021 Time Collected 10:15 AM
 Sample Collector Eric Rogers
 Date Printed 2/1/2021

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION ng/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
Perfluorooctanoic acid	<1.79	10 ng/L	1.79	EPA 537	1/28/21	10861
Perfluorooctane Sulfonate	<1.79	10 ng/L	1.79	EPA 537	1/28/21	10861

Surrogate Recovery %
 MPFHxA 75.6
 M3HFPO-DA NR
 MPFDA 79.6
 D5-N-EtFOSAA 88.4

<u>PARAMETER</u>	<u>CONCENTRATION ug/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	1/18/21	11549
Surrogate Recovery %						
1,4-Dioxane-d8	85.8					

Legend: RL = Report Limit
 MCL = Maximum Contamination Level
 NR - Not Reported

Comments



SAMPLE BLANK

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION</u> ng/L	<u>RL</u>	<u>METHOD</u>	Date Analyzed	Lab #
Perfluorooctanoic acid	Not Tested		EPA 537		10861
Perfluorooctane Sulfonate	Not Tested		EPA 537		10861
Surrogate Recovery %					
MPFHxA					
M3HFPO-DA					
MPFDA					
D5-N-EtFOSAA					

Comments