

SAMPLE INFORMATION

Sample ID

JH2004695

Supply Code

1952

Federal Water Supply Code NY5730106

Public Water Supply

Town of Salem Water Department

Address PO Box 57, 53 Stanton Hill Road City Salem

State NY

12865

Sample Location MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap

Date Collected

7/8/2020

Time Collected

9:05 AM

Free Chlorine 1.34 mg/L

Sample Collector Eric Rogers

Date Printed 7/21/2020

EPA METHOD 524.2 Trihalomethanes (THM's)

Date Analyzed 7/16/20

NYS Lab 11549

ANALYTE	CONCENTRATION UG/L	MCL*	METHOD
Chloroform	22.2		EPA 524.2
Bromodichloromethane	3.19		EPA 524.2
Chlorodibromomethane	0.860		EPA 524.2
Bromoform	<0.500		EPA 524.2
Total Trihalomethane	26.3	80 ųg/l	

MCL* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample