



**LABORATORY REPORT**

<b>Sample ID</b>	JH2004692	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106	<b>DOH</b>	Glens Falls
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road Salem , NY 12865		
<b>Sample Location</b>	Finished Water		
<b>Date Collected</b>	7/8/2020	<b>Time Collected</b>	10:00 AM
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	7/24/2020		
<b>Date Entered</b>	7/24/2020		

**Part V Table 8B Inorganic Chemicals & Physical Characteristics**

<b>Table 8B</b>					
<b>ANALYTE</b>	<b>CONCENTRATION mg/L</b>	<b>MCL</b>	<b>METHOD</b>	<b>Date analyzed</b>	<b>NYS Lab</b>
Arsenic	<0.0010	0.01	EPA 200.8	7/22/2020	11549
Barium	0.136	2.00	EPA 200.8	7/22/2020	11549
Cadmium	<0.0010	0.005	EPA 200.8	7/22/2020	11549
Chromium	<0.0010	0.10	EPA 200.8	7/22/2020	11549
Mercury	<0.00020	0.002	EPA 245.1	7/21/2020	11549
Selenium	<0.0051	0.05	EPA 200.8	7/22/2020	11549
Fluoride	<0.200	2.2	EPA 300.0	7/15/2020	11549

	<b>mg/L</b>	<b>MCL</b>	<b>METHOD</b>	<b>Date analyzed</b>	<b>NYS Lab</b>
Antimony	0.0008	0.006	EPA 200.8	7/22/2020	11549
Beryllium	<0.0003	0.004	EPA 200.8	7/22/2020	11549
Nickel	0.0012	0.1	EPA 200.8	7/22/2020	11549
Thallium	<0.0003	0.002	EPA 200.8	7/22/2020	11549
Cyanide	<0.0100	0.2	EPA 335.4	7/17/2020	11549

<b>Table 8C</b>	<b>mg/L</b>	<b>set up time</b>	<b>MCL</b>	<b>METHOD</b>	<b>Date analyzed</b>	<b>NYS Lab</b>
Nitrate°	NT		10 mg/l as N	Hach 10206		
Nitrite	NT		1 mg/l as N	SM18-4500-NO2 B		