



JH CONSULTING GROUP,
INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH1904557	Supply Code	1952
Federal Water Supply Code	NY5730106		
Public Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road	City	Salem
		State	NY
		Zip	12865
Sample Location	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap		
Date Collected	7/9/2019	Time Collected	8:15 AM
		Free Chlorine	mg/L
Sample Collector	Eric Rogers		
Date Printed	7/29/2019		

EPA METHOD 524.2 Trihalomethanes (THM's)	Date Analyzed	7/11/19	NYS Lab	10350
---	----------------------	---------	----------------	-------

ANALYTE	CONCENTRATION UG/L	MCL*	METHOD
Chloroform	6.9		EPA 524.2
Bromodichloromethane	2.1		EPA 524.2
Chlorodibromomethane	<1.0		EPA 524.2
Bromoform	<1.0		EPA 524.2
Total Trihalomethane	9.0	80 ug/l	

Notes:

MCL* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample
The surrogate recoveries for 4-fluorobenzene and 1,2-Dichlorobenzene-d4 for this sample were within acceptance limits at 98 and 104% respectively. The acceptable limits are 80-120%. The accompanying trip blank was found to be less than the reporting limits for trihalomethanes.