



JH CONSULTING GROUP, INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE ID#	JH1805675	SUPPLY CODE	1952				
PUBLIC WATER SUPPLY	Town of Salem Water Department	FEDERAL ID#	NY5730106				
ADDRESS	PO Box 575 Salem NY 12865	DOH	Glens Falls				
SAMPLE LOCATION	Drill Well #3 - Raw Water	E-mail	SalemVwd@Verizon.net				
DATE COLLECTED	7/24/2018	TIME COLLECTED	10:53 AM	SAMPLER	Eric Rogers	Date Printed	8/9/2018

Volatile Organic Chemical Analysis		EPA Method 524.2 Table 9B	NYS Lab	10350	Date Analyzed	8/2/2018
PARAMETER	CONCENTRATION UG/L	MCL	PARAMETER	CONCENTRATION UG/L	MCL	
BENZENE	<0.5	5	2,2-DICHLOROPROPANE	<0.5	5	
BROMOBENZENE	<0.5	5	1,1-DICHLOROPROPENE	<0.5	5	
BROMOCHLOROMETHANE	<0.5	5	1,3-DICHLOROPROPENE (TOTAL)	<0.5	5	
BROMOMETHANE	<0.5	5	ETHYLBENZENE	<0.5	5	
N-BUTYLBENZENE	<0.5	5	HEXACHLOROBUTADIENE	<0.5	5	
SEC-BUTYLBENZENE	<0.5	5	ISOPROPYLBENZENE	<0.5	5	
TERT-BUTYLBENZENE	<0.5	5	P-ISOPROPYLtolUENE	<0.5	5	
CARBON TETRACHLORIDE	<0.5	5	METHYLENE CHLORIDE	<0.5	5	
CHLOROBENZENE	<0.5	5	N-PROPYLBENZENE	<0.5	5	
CHLOROETHANE	<0.5	5	STYRENE	<0.5	5	
CHLOROMETHANE	<0.5	5	1,1,1,2-TETRACHLOROETHANE	<0.5	5	
2-CHLOROTOLUENE	<0.5	5	1,1,2,2-TETRACHLOROETHANE	<0.5	5	
4-CHLOROTOLUENE	<0.5	5	TETRACHLOROETHENE	<0.5	5	
DIBROMOMETHANE	<0.5	5	TOLUENE	<0.5	5	
1,2-DIBROMOETHANE	<0.5	5	1,2,3-TRICHLOROBENZENE	<0.5	5	
1,2-DICHLOROBENZENE	<0.5	5	1,2,4-TRICHLOROBENZENE	<0.5	5	
1,3-DICHLOROBENZENE	<0.5	5	1,1,1-TRICHLOROETHANE	<0.5	5	
1,4-DICHLOROBENZENE	<0.5	5	1,1,2-TRICHLOROETHANE	<0.5	5	
DICHLORDIFLUOROMETHANE	<0.5	5	TRICHLOROETHENE	<0.5	5	
1,1-DICHLOROETHANE	<0.5	5	TRICHLOROFLUOROMETHANE	<0.5	5	
1,2-DICHLOROETHANE	<0.5	5	1,2,3-TRICHLOROPROPANE	<0.5	5	
1,1-DICHLOROETHENE	<0.5	5	1,2,4-TRIMETHYLBENZENE	<0.5	5	
CIS-1,2-DICHLOROETHENE	<0.5	5	1,3,5-TRIMETHYLBENZENE	<0.5	5	
TRANS-1,2-DICHLOROETHENE	<0.5	5	VINYL CHLORIDE	<0.5	2	
1,2-DICHLOROPROPANE	<0.5	5	M-XYLENE	<0.5	5	
1,3-DICHLOROPROPANE	<0.5	5	O-XYLENE	<0.5	5	
Methyl Tert Butyl Ether	<0.5	10	P-XYLENE	<0.5	5	

Notes The surrogate recoveries of 4-Bromofluorobenzene and 1,2-Dichlorobenzene-d4 for this sample were within acceptance limits at 97 and 88%. respectively. The acceptance limits are 80-120%.

The accompanying trip blank was found to be less than the required detection limit for POC/VOC
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards