

SALEM WATER DEPARTMENT
53 STANTON HILL ROAD, SALEM, NY 12865
Phone and fax 854-9712
MONTHLY REPORT
April 13th 2015

- **There are 306 meters in service.**
- **1st 10 days of April I did water checks and minimal up keep.**
- **The monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225 for the month of March. Also did Iron and Manganese 1st quarter sample in March next one is due in June.**
- **Regular upkeep and maintenance was performed.**
- **Talked to DOH. Recommended that we keep working well #3 and keep it available if needed. In the next up coming weeks I will be trying to come up with a detailed plan on getting on a 3 year flushing / cleaning of wells starting with well #3 being the 1st one on the list.**
- **Water tank should be on a cleaning / checking plan to maintance a safe and clean talk. Last check was in 2013 and I would like to look into having it cleaned every 6th years and inspected every 3rd. There is companies that can clean a tank and keep it online.**
- **There is a water school in Middle of May I would like to attend. This will get me credits tords renewal and there is a lot of information available at it. The village**
- **We are doing Hydrant flushing the 1st week of May. This should take 3-4 days. If you get dirty water let it run till it's clean.**

Thank You,
Eric Rogers

Water Operator