

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

**April 14<sup>th</sup> 2021 Wednesday 7pm**

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We got new internet at the water barn. Spectrum got hooked up and seems to be working way better than our other one did.
- We flushed all the fire hydrants and re-flushed the dead ends. The system is ready for the summer. Flushing went very good.
- We did flow test and static lost tests on a couple fire hydrants near the old CB Sports building. I'm waiting on to hear back on what the flows are.
- We did a hand full for Dig Safe mark outs.
- All Fire Hydrants are in service
- We did our 2<sup>nd</sup> PFO round of testing. Hope it comes back like 1<sup>st</sup> round did and hopefully we should be set with that.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We need to have the office door at the water barn replaced - will do in spring.
- Worked on the year end reports for the water system and trying to get more information together to be able to get it on the town web page.

\* We will be washing the outside of the water tank

\* Travis and I have been trying to do "FREE" water training classes as we have found them. There has been a couple web training that we have done.

Thank You,

**Eric Rogers**

Class C Water Plant Operator