

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

August 8th Wednesday 7pm

- There are 314 meters in service.
- We had 3 new hook ups for the month of July.
- We went to a water class in Lake George for \$20 each. It was a good class. The class was on the 18th July. Its on Safety for water operators. It covered Excavations, Confined Space, Traffic Control and PPE.
- Regular upkeep and maintenance was performed.
- We did more of dead end flushing. We mix the flushing up into 2 parts NORTH & SOUTH. We do the every other week and on the off week we run different dead ends lite.
- I did a meter read.
- The County help install a flushing pipe on RT64 so we will have a good place & safe place to flush the last hydrant
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- All fire hydrants are in service.
- We did our Nitrate, Lead and Copper, Secondary Inorganic Chemicals, Principle Organic Chemicals. I would like to thank the home owners that were willing to do the lead and copper tests for me. I'm still waiting on the Lead and Copper test to come back, ALL others have came back and are good. If anyone would like to see them the results are in the water office.
- On the 14th of August I will be meeting with Kevin Maine, Program Specialist from New York Rural Water Allocations to have him look over the Water office to see if he can find any energy saving. This will be a free service.
- Our up coming water tests this year are
 - Coliform - Monthly
 - Iron + Manganese - Quarterly (March,June,September,December)

Thank You,

Eric Rogers

Class C Water Plant Operator

* We had talked to (Airo Smith Development) about them putting a cell tower up near the water tank. Could we look back into that and see if they would be interested still

- It could be an easy extra income for the water department.