

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

## **August 11<sup>th</sup> 2021**

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Have been working priming and painting fire hydrants and then install new bolts. I am hoping that the hydrant near the school will be painted by the school in Salem Generals colors like other water systems do. Working on 25 hydrants. I have about 10 left to finish.
- The mapping program is up for its yearly renewal. This is very handy and I think well worth the money.
- We did a hand full for Dig Safe mark outs.
- We did a hand full of water tests this month - waiting in results to come back.
- Grass has been growing fast and have been mowing it down at water barn.
- We got our computer fixed at the water barn + now the computer is down again at the water barn. We need a big update to get back to normal running conditions. We can monitor the system from the auto dial / alarm system but need it to be fixed / replaced
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced
- Talked with Mark Rogers and hope to be doing a well clean soon.

Thank You -

**Eric Rogers**

Class C Water Plant Operator