

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

## **December 12<sup>th</sup> Wednesday 7pm**

- There are 314 meters in service.
- We had no new hook ups for the month of December.
- Regular upkeep and maintenance was performed.
- We pulled well #3 pump did checks on it and put back in well. The VFD for well pump #3 is bad. The pump can run in hand mode by-pass BUT will not run in regular mode. We took 2 samples from well #3 to make sure its safe to drink from. Mark Rogers ordered a new drive and will contact me once it comes in. I will keep the board up to date as I find out more.
- All Hydrants have been pumped out and are ready for winter. I ask if any hydrant is used to contact the water department so it can be re-pumped.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are in service.
- We have changed our pump setting for Chlorine and K5. It seems to be working good. We hope to use less K5 with less waste.
- I did a monthly meter read.
- Our up coming water tests this year are
  - Coliform - Monthly
  - Iron + Manganese - Quarterly (December)

Thank You,

**Eric Rogers**

Class C Water Plant Operator

- 16 street lights were called in to be fixed. Anyone can do this on line. I would be more than happy to show how.