

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

December 8th 2021

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Got a check and gave it to Travis for the 5 Park Place hookup. They got a 2” meter and all parts from our side to hook up. Hoping once they get some heat to be doing the turn on soon.
- Got system all ready for the up coming cold months.
- We had one 3/4” water meter freeze at a home that is having work done and was open to the weather. Please close off your basement windows and if you have a cold basement insulate your pipes so your not next!
- All fire hydrants have been winterized and ready for winter.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We need to have the office door at the water barn replaced
- Will be doing 4th quarter Iron and Manganese in December also started my end of the year water withdraw DEC paperwork.

*****If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze*****

Thank You,

Eric Rogers

Class C Water Plant Operator