

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

February 12th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- Mark Rode came in and did the computer updates that were out to bid. Everything seems to be going good.
- NY Fire came in and did what was out to bid. All in and seem to be working good.
- Did a monthly meter read.
- We did a hand full for Dig Safe mark outs.
- All Fire Hydrants are in service - and set for winter. I pumped them all out and made sure all caps can come off easy and also checked oil and changed markers that needed changing.
- We got the lighting fixed around the water office.
- We had 3 water meter's freeze in the water district.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced - will do in spring.
- We did our 1st round of PFOA - PFOS and 1,4 Dioxane testing and the test came back GOOD. 2nd round is due for April 2021.
- Worked on the year end reports for the water system.

*** If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze.**

*** Hopefully all hydrant dead end flushing will be done til spring.**

Thank You,

Eric Rogers

Class C Water Plant Operator