

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

January 11th 7pm 2017

- There are 310 meters in service.
- There was no new water hook ups this month.
- At the end of the year 2016-2017 we pumped about 12.1 million gallons from pump 1, 6.8 million gallons from well 2, and .5 million gallons from well 3. This gives a total of just under 19.5 million for the year of 2016.
- Regular upkeep and maintenance was performed.
- We did a meter reading. The 1st on unloaded and could not be located so we did a 2nd reading and this time it worked like it should of. We got 90% read / there was 32 no reads – 3 tampers – 22 leaks.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- I did the monthly and year end paperwork.
- One dig safe mark-out was done.
- The 2 back flow preventers at the water office got their yearly inspection. They both passed. One is on the in line near the meter and the other is for the boiler.
- I have done a couple of the FEMA (IS) classes for water credits. I did IS-100b, IS-200b, IS-700a and IS-800b.

Thank You,

Eric Rogers

Class C Water Plant Operator