

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email [salemvwd@verizon.net](mailto:salemvwd@verizon.net)

## **January 10<sup>th</sup> Wednesday 7pm**

- There are 311 meters in service.
- We did our 4<sup>th</sup> quarter Iron and Manganese tests.
- Regular upkeep and maintenance was performed.
- Still working with Badger meter on our new read software. I hope it will be up and running soon so we can then start working on replacing meter heads to get a better read percent.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are winterized. If used please notify the water dept.
- We had a week or 2 of below 0 degrees which gave a spike in water usage. We checked and look the best we could to find the problems and fix them before they became big issues. We have 2 fire hydrants running so a couple water mains that we have had issues with in years back will not freeze.
- Working on a spring time to do list and also some up coming projects and some new equipment that we will be needing.

Thank You,

**Eric Rogers**

Class C Water Plant Operator