

# SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

## January 9<sup>th</sup> Wednesday 7pm

- There are 314 meters in service.
- We had no new hook ups for the month of December.
- Regular upkeep and maintenance was performed.
- Mark Rogers installed a new FVD for well #3. this drive is the same one we have on well #1. Well #3 is back up and running.
- \* Well #1 drive was new in 9/12/2008. Well #2 drive was new with the water system in 2003. looking at it - if we have any money left at the end of the 2019 year I want to replace it before we have an issue with it seeing it is going to be 16 years old.
- I would like to **THANK** Keven Baylor for donating a flag and putting it up at the Water Office.
- All Hydrants have been pumped out and are ready for winter. I ask if any hydrant is used to contact the water department so it can be re-pumped.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are in service.
- We have changed our pump setting for Chlorine and K5. It seems to be working good. We hope to use less K5 with less waste.
- I did a monthly meter read.
- Our up coming water tests this year are

I am waiting on the 2019 testing report to be sent to me. Once I get it I will let you no what we have to test for in the 2019 year. I do no we need to do monthly bacteriological tests. We will also have to do 4 quarterly Iron and manganese tests (March - June - Sept - Dec).

Thank You,

**Eric Rogers**

Class C Water Plant Operator

