

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax(518)854-9712 --- Email: salemwaterdept@gmail.com

**January 8<sup>th</sup> Wednesday 7pm**

- I would like to thank everyone that cleans out around any fire hydrants with in the water district. This helps us out and also would be a great help if they are needed before the water dept has a chance to clean them.
- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- Did a couple mark outs for Dig Safe.
- We are still having water tank communication issues. We are working on getting it fixed.
- All fire hydrants have been pumped out for winter. If a hydrant gets used please let the Water Department know so we can re-pump it out. All hydrants looked good and are in service.
- I fixed a couple no read meter heads. Will be working on this.
- The 2 back flow preventer's at the water barn passed and will be good for at less another year.
- Eye wash and Fire Extinguishers checks have been done. We had our yearly Fire Extinguisher inspection done. All looked good.
- We did our monthly water sample required by the D.O.H. it met the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- I went to a FREE water school 12/10. this was a good class on line location and leak detection.
- I am working with Rural Water on trying to update some information for the office and also trying to stay 1 step ahead of the Department of health with required paperwork. I'm still trying to push for the Diamond Mapping as well.

Thank You,

**Eric Rogers**

Class C Water Plant Operator

I am waiting on the 2020 testing report to be sent to me. Once I get it I will let you no what we have to test for in the 2019 year. I do no we need to do monthly bacteriological tests. We will also have to do 4 quarterly Iron and manganese tests (March - June - Sept - Dec).

