

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

July 10th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We have been flushing dead end fire hydrants to keep water moving.
- We did a hand full for Dig Safe mark outs.
- Fixed Hydrant #37.
- We did our 2nd quarter Iron and Manganese test.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are in service
- I have changed a couple more no read meter heads. I hope to do more for them on rain days.
- We need to have the office door at the water barn replaced.
- Did flow tests (pre) on well #1 & #2. We cleaned both wells and then did flow tests again (post). Everything went good waiting on reports to come back. DOH seemed happy and we tested both wells before turning them back on line.
- We had an issue with the radio's that talk from main computer to the water tank. We had to run wells manually for a couple weeks till we got General Controls to come out and get the right parts and replace. It is back to running normal again. They will be back soon once last part comes to put surge protection back at the tank. The old radio's were new in 2003 and were obsolete so they had to replace not just repair.

Thank You,

Eric Rogers

Class C Water Plant Operator

