

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

July 14th
2021

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Have been working priming and painting fire hydrants and then install new bolts. I am hoping that the hydrant near the school will be painted by the school in Salem Generals colors like other water systems do. Working on 25 hydrants. I have about 10 left to finish.
- The mapping program is up for its yearly renewal.
- We did a hand full for Dig Safe mark outs.
- Our Iron and Manganese testing for June is done - 2nd quarter
- Grass has been growing fast and have been mowing it down at water barn.
- The week of July 12th I will be doing a big group of water samples to JH Consulting that is required. There is 2 coolers full of tests that need to be done.
- With our PFO sampling coming back good we don't have to test it anymore for this year.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We need to have the office door at the water barn replaced
- Talked with Mark Rogers and hope to be doing a well clean soon.
- Mark Rode will be coming to work on the main water computer. The computer died over the 4th of July week. We can still run normal but have to monitor it from different electrical devices.

Thank You,

Eric Rogers

Class C Water Plant Operator