

**SALEM WATER DEPARTMENT
53 STANTON HILL ROAD, SALEM, NY 12865
Phone and fax 854-9712**

**MONTHLY REPORT
June 8th 2016**

- There are 309 meters in service. 1 new turn on this month. (Fire House)
- I did 3 house re-turn on “winter” also turned on the 3 seasonal meters.
- The monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- In June I will have to do my 2nd quarter Ir and Mn test,
- Regular upkeep and maintenance was performed.
- I ordered the spare parts we needed for our chemical pumps.
- I did Fire Hydrant flushing. It went good with just one fire Hydrant needing to be fixed.
- Hope to have Fire House Hydrant turned by end of June.
- Eric went to water school this past month to get hours so my license will be able to renew in a couple more years when needed.
- Have been talking to Mark Rogers and DOH about flushing—cleaning of well #3. I also have talked to DOH about the water tank. I might of found a local talk cleaning company that could clean out the tank and also do a video “underwater” inspection of the tank.
- At a different time I would like to talk to the water committee and any other board members interested about getting our extra parts up to compliance and setting a price if any to be billed if a part is needed. (No lead in brass) going to need new meter spare parts.

**Thank You,
Eric Rogers
Class C Water Plant Operator**