

**SALEM WATER DEPARTMENT  
53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865  
Phone and Fax 854-9712 --- Email salemvwd@verizon.net**

**March 8<sup>th</sup> 7pm 2017**

- There are 309 meters in service.
- There was one new water hook up this month.
- Regular upkeep and maintenance was performed.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. This sample MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- I would like to meet up with Seth and we can work on the EDU issues – problems we have on the water.
- I would like the Board to look into amending the (Rules and Regulations) for the Water Dept. It was last updated March 2, 2011.
- We had the boiler at the water office inspected. It passed and looked good.
- We had 1 water turn off for the month.
- We did a meter read. Seth gave me some info on a company that does metering and data. I would like to talk to them to see what they can offer.
- The Salem Fire Department did a drill on fire hydrant 63. We had to pump it out after to prevent the hydrant from freezing.

-----

- There will be a water school in Saratoga this year. I left the information on Seth's desk and hope we can go. The Class is 1 day and is only \$60 per operator.
- Travis and I will be going to a water FREE water school this month.

**Thank You,**

**Eric Rogers**

**Class C Water Plant Operator**

**\*Please post in the paper – We will be doing our spring hydrant flushing the week of the 17<sup>th</sup> – 21<sup>st</sup> April.**